



CITY OF FRISCO PURCHASING DIVISION

December 16, 2011

Addendum #2

Question and Answer & Specification clarification

This Addendum is issued to address various questions submitted during the question/answer timeframe, which ended 12/15/11

Bid Number #1212-025

Community Park Water Well Project

1. Section P1, "Pump house shall be a commercially manufactured, insulated, fiber class Pump House of adequate size". *Contractor shall be required to provide the owner with a commercial grade pump house. It shall have the ability to be locked as manufactured by Dyer Fiberglass or approved other. Contractor shall provide a pump house cut sheet, prior to instillation, to be approved by owner.*
2. Paragraph W3b states a "seven (8 5/8) casing size". *The casing size shall read eight and five eighths (8 5/8) throughout the project manual.*
3. Paragraph W5 called for a 75-100 gpm rate for testing the well. *The test pump shall be required to produce a minimum of 250 GPM.*
4. Paragraph WP2 calls for a Grundfos 150S400-18 pump. *The pump shall be A Wolf 6MM8V-13 or approved other shall be required. Pump shall produce 250 GMP*
5. Hole cutting and drilling mud disposal options. *All cuttings shall be the contractor's responsibility to haul off site and dispose of legally. The Owner will allow the drilling mud for SITE C to be disposed of into the existing lake, cuttings will need to be hauled off site and disposed of legally.*
6. *In accordance with section 17. of the bid specifications, the City reserves the right award a separate contract(s) to separate bidders. Therefore, bidders can NO BID one or two wells if they so choose.*
7. *All references to the three and one half inches (3 1/2") pump column shall be revised to read Four inches (4") throughout the documents and the bid forms. BIDS MUST BE SUBMITTED USING THE REVISED BID FORM BELOW.*
8. *The test hole shall be twelve and one quarter inches in diameter (12 1/4")*
7. *Contractor is responsible for providing power / temporary power at all well locations for all drilling and casing operations as well as for the test pump operation.*
8. ***THE BID OPENING HAS CHANGED.** The Bids are due no later than 2:00 p.m. on December 22, 2011. Bids will be read at 2:05 p.m. on December 22, 2011. **Bids must be received by "Thursday December 22, 2011 at 2:00 PM by the Director of Administrative Services. No bids will be accepted after that date and time. All bids received after this time will not be considered.***



CITY OF FRISCO PURCHASING DIVISION

REVISED - BID FORM
 Bid Number 1212-025
 "Community Park Water Well Project"

	Well "A" (Frisco Commons Park)	Units	Budgeted Qty.	Unit Cost	Extended Cost
	Test Hole	LF	1,650		
	8 5/8" OD Steel Casing	LF	1,450		
	4 1/2" OD ssww barlug screen	LF	160		
	4 1/2 OD Blank Liner	LF	140		
	Pump 250 gpm @ 900 feet of total Head	LS	1		
	4 1/2 OD pump column, cable & airline	LF	1,000		
	Motor – 75 HP	LS	1		
	Float Sensor	EA	1		
	4" PVC Drain to Lake	LF	250		
	4" PVC Pipe to Splash Pad	LF	1500		
	Pump House	LS	1		
	3" Meter attached to well head per Underground Water Board Regulations.	LS	1		
	Owners Contingency	LS	\$20,000		
SUB TOTAL →					

Total Number of Days to complete from Notice to Proceed:

Item	Well "B" (Warren Sports Complex)	Units	Budgeted Qty.	Unit Cost	Extended Cost
	Test Hole	LF	1,650		
	8 5/8" OD Steel Casing	LF	1,450		
	4 1/2" OD drop pipe	LF	160		
	4 1/2 OD Blank Liner	LF	140		
	Pump 250 gpm @ 900 feet of total Head	LS	1		
	4 1/2 OD pump column, cable & airline	LF	1,000		
	Motor – 75 HP	LS	1		
	Float Sensor	EA	1		
	4" PVC Drain to Lake	LF	350		
	Pump House	LS	1		
	3" Meter attached to well head per Underground Water Board Regulations.	LS	1		
	Owners Contingency	LS	\$20,000		
SUB TOTAL →					
Total Number of Days to complete from Notice to Proceed:					

Item	Well "C" (Harold Bacchus Park)	Units	Budgeted Qty.	Unit Cost	Extended Cost
	Test Hole	LF	1,650		
	8 5/8" OD Steel Casing	LF	1,450		
	4 1/2" OD drop pipe	LF	160		
	4 1/2 OD Blank Liner	LF	140		
	Pump 250 gpm @ 900 feet of total Head	LS	1		
	4 1/2 OD pump column, cable & airline	LF	1,000		
	Motor – 75 HP	LS	1		
	Float Sensor	EA	1		
	4" PVC Drain to Lake	LF	130		
	Pump House	LS	1		
	3" Meter attached to well head per Underground Water Board Regulations.	LS	1		
	Owners Contingency	LS	\$20,000		
SUB TOTAL →					
Total Number of Days to complete from Notice to Proceed:					

Please provide final bid tabulations in both words and numbers:

Base Bid

Well A _____

Well B _____

Well C _____

Total Base Bid _____

(Total number of days to complete) _____

Alternate 1: Deduct Well A _____

(Total number of days to complete) _____

Alternate 2: Deduct Well B _____

(Total number of days to complete) _____

Alternate 3: Deduct Well C _____

(Total number of days to complete) _____

Measurement and payment for the various bid items will be made in accordance with the item as set up in the Bid. Quantities stated in the Bid are approximate and are to be used only as a basis for estimating the probable cost of work. The Contractor will only be paid for the actual amount of work done and the material furnished. The Contractor will make no claim for damages, restocking or anticipated profits caused by any differences found between the quantities of work actually done and the estimated quantities in the Bid. The Owner also reserves the right to delete portions of this project. If a position of work is deleted, no claim can be filed for damages, restocking or anticipated profits. Any quantities added to this project will be paid for at the unit price bid for that item.

The undersigned certifies that the bid prices contained in this bid have been carefully reviewed and are submitted as correct and final. Bidder further certifies and agrees to furnish any and/or all product/service upon which prices are extended at the price offered, and upon the conditions in the specifications of the Invitation For Bid.

I hereby certify that the foregoing bid has not been prepared in collusion with any other bidder or other person or persons engaged in the same line of business prior to the official opening of this bid. Further, I certify that the bidder is not now, nor has been for the past six (6) months, directly or indirectly concerned in any pool or agreement or combination to control the price of product/service bid on, or to influence any person or persons to bid or not to bid thereon."

Name of Bidder: _____

Address of Bidder: _____

Telephone Number: _____ Fax: _____

E-mail address: _____

By: _____(print name) Cash Discount Terms:_____

Title: _____Federal ID #/SSN #: _____

Signature: _____

Acknowledgement of Addenda: #1 ____ #2 ____ #3 ____ #4 ____ #5 ____

Vendors who may have already submitted a bid and feel this addendum may change their bid price, may pick up their bid, and return it by the closing date. If picking up the bid is not feasible, any new bid submitted by your firm will supersede one previously submitted. Acknowledge receipt of this addendum by initialing in the appropriate space on the bid document.

Sincerely,

Wes Hicks
Parks Project Coordinator
City of Frisco